

THIS IS TO CERTIFY THAT

# HORNE ENGINEERING Ltd

has had the following products Certified by BuildCert Limited  
to the requirements of

**BS EN 1111:1999 Thermostatic Mixing valves (High pressure)<sup>(1)</sup>**  
**BS EN 1287:1999 Low pressure Thermostatic Mixing valves<sup>(1)(2)(3)</sup>**

Products covered by this certification include

**Heatstat T2**  
**Having 22mm inlet/outlet connections.**  
**Incorporating integral check valves and strainers.**



Signature

20<sup>th</sup> of May 2004.

Date

Certificate: BC071/0204  
Type Test & QMS.  
Issue Date 3<sup>rd</sup> February 2004  
Expiry Date 3<sup>rd</sup> February 2009



(1) Excluding dimensional and acoustic requirements.  
(2) Excluding bath use at 0.1 bar supply pressure.  
(3) Meets the bath flowrate requirement at 0.2 bar supply pressure