



UK APPROVAL (ATS3)
Certificate Number: 2002725

Date Issued: 27 February 2020
Date Expired: 26 February 2025

Description: Manual diverter incorporating two spherical valves controlling both the hot and cold flow. Maximum working pressure 10.0 bar. Maximum operating temperature 85°C.

Product Designation: ILTDU

This is to certify that the above range of products manufactured / supplied by

Company Name: Horne Engineering Ltd

has been tested and found to comply with the requirements of the Water Supply (Water Fittings) Regulations 1999 for England and Wales, the Water Byelaws 2014, Scotland and the Water Regulations Northern Ireland.

This certificate must be read in conjunction with the acceptance letter for this product.

This approval is intended for compliance with the above Regulations and must not be considered equivalent to the product certification provided by Kiwa N.V.

To comply with the Regulations and Byelaws all products require the correct installation. Details of the installation requirements (IRN's) can be obtained from the acceptance letter supplied with this certificate.

Applicable IRN's for this certificate – R001, R120

Authorised Signature

CERTIFICATE

Kiwa Watertec
(A Trading Division of
Kiwa Ltd)
Unit 26A
Rassau Industrial Estate
Ebbw Vale, Gwent,
NP23 5SD
UNITED KINGDOM
Tel: 0044 (0) 1495 308185
Web: www.kiwa.co.uk

Certificate Issued to –
Horne Engineering Ltd
PO Box 7
Rankine Street
Johnstone
PA5 8BD

