



Certificate number: 2104718

Date issued 28th April 2021

Date expired 27th April 2026 Original/Amendment *Original*

Kiwa UK Regulation 4 (KUKreg4) Approval

ATS3 – Without Production Surveillance

Issued by Kiwa Watertec (UK)

Evaluation Guideline: Kiwa UK – EG004
Reference Standards: Regulators Specification
Model Designations: see Appendix

Manufacturer: Horne Engineering Ltd.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied on to comply with the above Evaluation Guideline and Standards, and can be marked with the KUKreg4mark.

The intended use of this certificate is for compliance with Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales; 2009 Northern Ireland and 2014 Byelaws Scotland

This certificate has been issued in accordance with the Kiwa regulations for product certification

Signed on behalf of Kiwa Watertec

David Jay,
Business Unit Manager – Authorised Signatory
Kiwa Watertec

CERTIFICATE

3901770301

Kiwa Watertec
(A Trading Division of Kiwa Ltd)
26A Rassau Industrial Estate
Ebbw Vale
Gwent
NP23 5SD
United Kingdom
T +44 (0)1495 308185
uk.water@kiwa.com
www.kiwa.co.uk

Certificate issued to:
Horne Engineering Ltd
Rankine Street
Johnstone
PA5 8BG



UK Approval Certificate (page 2 of 2)

Appendix to Certificate 2104718

The following products are covered by this certificate -

PRODUCT DESCRIPTION T-type thermostatic mixing valve having a brass body. Inlets incorporate a stainless steel strainer situated within an angled inlet and single check valve. Adjustment of the valve is made using the adjustment key. ATS3 – Without Production Surveillance.
MODEL(S) Horne 25 Type H2501.
SIZE: 28mm Compression.
SCOPE: Manufacturer recommended maximum working pressure 10 Bar & maximum operating temperature 85°C. Hygienic Purposes: Non-metallic materials suitable for continuous use up to 85°C. Above ground use only.
MATERIALS Non-metallic materials assessed (BS6920) to point of discharge.
BACKFLOW PROTECTION NOTES Check valve cartridges at cold and hot inlets suitable for backflow protection.
MARKING Horne 25, Horne Eng Co, Type No H2501 on body.
ADDITIONAL NOTES All water contact & exposed components satisfy opacity requirements.

Extra Notes