



# CERTIFICATE

**UK APPROVAL (ATS3)**  
**Certificate Number: 2003746**

Date Issued: 19 March 2020  
Date Expired: 18 March 2025

**Description:** 'DUSO' shower column with black plastic spray plate operated by a hydraulically actuated self closing push paddle control. Maximum working pressure 5.0 bar. Maximum operating temperature 50°C. Maximum working pressure 5 bar. Maximum operating temperature 60°C.

**Product Designation:** DS-A60B (Black)

This is to certify that the above range of products manufactured / supplied by

**Company Name: Horne Engineering Ltd**

has been tested and found to comply with the requirements of the Water Supply (Water Fittings) Regulations 1999 for England and Wales, the Water Byelaws 2014, Scotland and the Water Regulations Northern Ireland.

This certificate must be read in conjunction with the acceptance letter for this product.

This approval is intended for compliance with the above Regulations and must not be considered equivalent to the product certification provided by Kiwa N.V.

To comply with the Regulations and Byelaws all products require the correct installation. Details of the installation requirements (IRN's) can be obtained from the acceptance letter supplied with this certificate.

Applicable IRN's for this certificate – R001

Authorised Signature

Kiwa Watertec  
(A Trading Division of  
Kiwa Ltd)  
Unit 26A  
Rassau Industrial Estate  
Ebbw Vale, Gwent,  
NP23 5SD  
UNITED KINGDOM  
Tel: 0044 (0) 1495 308185  
Web: [www.kiwa.co.uk](http://www.kiwa.co.uk)

**Certificate Issued to –**  
Horne Engineering Ltd  
PO Box 7  
Rankine Street  
Johnstone  
PA5 8BD

