



UK APPROVAL
Certificate Number: 1810749

Date Issued: 11 October 2018
Date Expired: 10 October 2023

Description: Horne 'Optitherm' wall mounted thermostatic tap (chromium plated brass) with a quarter turn ceramic disk head work with the temperature being thermostatically controlled. Incorporating integral isolation valves and a single check valve on the inlet located within the body and stainless steel mesh filter on the inlet.

Maximum working pressure 5.0 bar & maximum operating temperature 85°C.

Product Designation: Horne Optitherm type TBT02

This is to certify that the above range of products manufactured / supplied by

Company Name: Horne Engineering Limited

has been tested and found to comply with the requirements of the Water Supply (Water Fittings) Regulations 1999 for England and Wales, the Water Byelaws 2000, Scotland and the Water Regulations Northern Ireland.

This certificate must be read in conjunction with the acceptance letter for this product.

This approval is intended for compliance with the above Regulations and must not be considered equivalent to the product certification provided by Kiwa N.V.

To comply with the Regulations and Byelaws all products require the correct installation. Details of the installation requirements (IRN's) can be obtained from the acceptance letter supplied with this certificate.

Applicable IRN's for this certificate - R001, R010, R040

Authorised Signature

CERTIFICATE

Kiwa Watertec
(A Trading Division of
Kiwa Ltd)
Unit 26A
Rassau Industrial Estate
Ebbw Vale, Gwent,
NP23 5SD
UNITED KINGDOM
Tel: 0044 (0) 1495 308185
Fax: 0044 (0) 1495 304496
Web: www.kiwa.co.uk

Certificate Issued to -
Horne Engineering Limited
PO Box 7
Rankine Street
Johnstone
PA5 8BD

